



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

April 24, 2008

SFA SANIFLO INC.
JOHAN BOUWER
105 NEWFIELD AVE SUITE A
EDISON NJ 08837

Re: Description: MACERATING TOILET SYSTEM
Manufacturer: SFA SANIFLO INC.
Product Name: SANIBEST AND SANIPLUS
Model Number(s): NONE
Product File No: 20060296

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The venting system of the connecting fixtures must conform to requirements of Comm 82.31 of the Wisconsin Administrative code
- The discharge pipe must connect to a sanitary drain system in accordance with Comm 82.30 (10) of the Wisconsin Administrative code.
- The venting system serving the macerating unit must conform to requirements of Comm 82.31 of the Wisconsin Administrative code, "vents for sumps".
- The Sanibest macerating unit may only accept waste from a lavatory and/or a bathtub with or without a shower. It MAY NOT accept waste from a shower unit.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov